

Fence
Permit Requirements

MUST HAVE ALL OF THE FOLLOWING
IN ORDER TO ACCEPT APPLICATION:

Wood Fence (All wood types):

- Building application: - Must include Lot, Block and subdivision, and job Value
- Include a survey showing the footprint of property and indicate the location and height of fence/width and location of gates to be installed.
- 2328.2
Fences not exceeding 6 feet (1829 mm) in height, shall be constructed to meet the following minimum requirements: from nominal 4-inch by 4-inch by 8-feet-long (102 mm by 102 mm by 2438 mm) posts No. 2 grade or better spaced 4-feet (1219 mm) on center, and embedded 2 feet (610 mm) into a concrete footing 10 inches (254 mm) in diameter and 2-feet (610 mm) deep.
- 2328.3
Fences not exceeding 5 feet (1524 mm) or 4 feet (1219 mm) in height shall be constructed as provided in Section 2328.2, except that the spacing of posts may be increased to 5-feet (1524 mm) and 6-feet (1829 mm) on center for these heights, respectively.
- Finish side of fence shall be to the outside and all posts or supports to be inside.

Aluminum, Vinyl, PVC and Decorative metal Fence (etc.)

- Building application: - Must include Lot, Block and subdivision, and job Value
- (Two copies) of the current product approvals or Specialty Engineer shop drawings signed and sealed.
- Must highlight all components, connections and method of anchorage on product approval or shop drawings.
- Include a survey showing the footprint of property and indicate the location and height of fence/width and location of gates. Indicate type of new fence to be installed.

Chain link Fence

- Building application: - Must include Lot, Block and subdivision, and job Value
- Include a survey showing the footprint of property and indicate the location and height of fence/ width and location of gates to be installed.
- **TABLE 2224 CHAIN LINK FENCE MINIMUM REQUIREMENTS**

454.2.17 Residential swimming barrier requirement Fence around **Swimming pools/Spa** shall have minimum height of 48” with self-closing/Latching gates with minimum height of 54” for latches from adjacent grade. Openings in any barrier shall not allow passage of a 4-inch-diameter sphere. Gates that provide access to the swimming pool must open outward away from the pool. Exception: If you have (a) Removable child Barrier fence 454.2.17.1.11 thru 15 (b) pool cover ASTM F 1346 (c) alarms in pool that meet ASTM Standard F2208. Please identify on plans.